

## **ARUBA SPA**

Via San Clemente, 53 - 24036 PONTE SAN PIETRO (BG) - Italy

## **Data Center Site**

Data Center "A": Via San Clemente, 53 – 24036 PONTE SAN PIETRO (BG) – Italy Data Center "B": Via San Clemente, 53 – 24036 PONTE SAN PIETRO (BG) – Italy Data Center "C": Via San Clemente, 53 – 24036 PONTE SAN PIETRO (BG) - Italy

Bureau Veritas Italia SpA certify that the Data Center of the above organisation has been audited and found to be in accordance with the requirements of the Standard detailed below

## ISO/IEC TS 22237:2018 Part 1-7

Scope of certification

## AS BUILT VALIDATION LEVEL: AVAILABILITY CLASS 4 – PROTECTION SECURITY CLASS 4

ARUBA SPA DATA CENTER "A"-"B"-"C" PONTE SAN PIETRO, FACILITIES AND COMPUTER ROOMS, INCLUDING SITE LOCATION, ARCHITECTURE, SECURITY, SAFETY, FIRE SUPPRESSION, ELECTRICAL, MECHANICAL AND TELECOMMUNICATION.

Original cycle start date:

20 October 2022

Expiry date of previous cycle:

N.A.

Certification/Recertification Audit date:

07 October 2022

Certification cycle start date:

20 October 2022

Subject to the continued satisfactory operation of the organization's Management System, this certificate expires on: **19 October 2025** 

Certificate No. - Version: IT318785-3

Revision date: 18 December 2023

PRD Nº 009B

Giorgio Lanzafame – Nocal Technical Manager

ACCREDIA 5.

Signatory of EA, IAF and ILAC mutual Recognition Agreement

Certification body address: Bureau Veritas Italia S.p.A., Viale Monza, 347 - 20126 Milano, Italia

Further clarifications regarding the scope of this certificate and the applicability of the management system requirements may be obtained by consulting the organization.

To check this certificate validity please refer to the website www.bureauveritas.it